



Provide weepholes to external cavity walls in the course immediately above flashings, cavity fill, and at the bottoms of unfilled cavities, to a maximum spacing of 1200mm. Weepholes must comply with AS 3700 clause 4.7.2 & AS 3700 clause 12.4.14 requirements. Where a BAL of 12.5 or greater applies, see AS 3959 for building in bushfire prone areas; weep holes will require a corrosion resistant wire mesh to prevent ingress of embers. Damp proof course to external walls in mortar course under weep holes and fixed to the frame. Damp proof course to AS/NZS 2904, AS3700 & AS4773.1 & 2

Weep Hole & DPC Detail

Scale:- NTS

Detail			
Weep Hole & DPC Detail			
Drawn by	C.M.B	Date	5/07/18
Checked		Date	

DIVERSEBUILDERS

P.O Box 196
114 Melville Street
Numurkah VIC 3636
T 03 5862 2712
F 03 5862 3583
E info@diversebuilders.com.au
W diversebuilders.com.au



WARNING:-
All information and designs contained within this document are copyright to Diverse Builders
RBP Reg No. DBU-8259 - CBU-6016 & NSW 89500C